



171120341434

检测报告

报告号: AJFS1711009986FF_CN 日期: 2017年11月27日 第 1 页 共 5 页

浙江索凡胶粘制品有限公司

浙江省湖州市安吉县天子湖工业园区五福路 5 号

以下测试样品为客户提供并确认:

产品描述: 墙布

SGS 参考号: HZIN1711002450PS

测试要求:

GB 50222-1995(2001 年修订) 建筑内部装修设计防火规范, 附录 A, A2.2 条顶棚、墙面、隔断装修材料 B1 级

测试结果: --- 参见数据附表---

测试周期:

样品收到日期 : 2017 年 11 月 10 日

测试执行周期 : 2017 年 11 月 10 日 至 2017 年 11 月 23 日

通标标准技术服务有限公司

授权代表签署

邹石龙
技术经理



SGS-CSTC Technical Services Co., Ltd.
Anji Branch Hardlines

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

No. 301, Sunlight Road, 2 Block, Sunlight Industry Zone, Anji County, Zhejiang Province, China 313300 t (86-572) 5018825 f (86-572) 5018829 www.sgs.com.cn
中国·浙江·安吉县阳光工业园二区阳光大道301号 邮编: 313300 t (86-572) 5018825 f (86-572) 5018829 e sgs.china@sgs.com

Member of the SGS Group (SGS SA)

检测报告

报告号: AJFS1711009986FF_CN 日期: 2017年11月27日 第2页 共5页

I. 测试标准

本测试按照 GB 50222-1995(2001 年修订) 建筑内部装修设计防火规范进行。测试方法基于

GB/T 8625-2005 建筑材料难燃性试验方法

GB/T 8626-2007 建筑材料可燃性试验方法

II. 测试摘要

试验方法	参数	样品数量	试验结果
GB/T 8625-2005	剩余长度平均值 (mm)	16	241
	平均烟气温度 (°C)		162.9
	是否有剩余长度为零		否
GB/T 8626-2007 施火时间 = 15 s	$F_s \leq 150 \text{ mm}$	6	是
	是否引燃滤纸		否

III. 分级要求:

A2.2 顶棚、墙面、隔断装修材料, 经难燃性测试, 同时符合下列条件, 应定为B1级

A2.2.1 试件燃烧的剩余长度平均值 $\geq 150\text{mm}$ 。其中没有一个试件的燃烧剩余长度为零。

A2.2.2 其中没有一组试验的平均烟气温度超过 200°C

A2.2.3 经过可燃性测试, 且能满足可燃性试验段条件。

A2.3 顶棚、墙面、隔断装修材料, 经可燃性测试, 同时符合下列条件, 应定为 B2 级

A2.3.1 对下边缘未加保护的试件, 在底边缘点火开始后的 20S 内, 五个试件火焰尖头均未到达刻度线

A2.3.2 对下边缘有保护的试件, 除符合以上条件外, 应附加一组表面点火试验, 点火开始后 20S 内, 五个试件火焰尖头均未到达刻度线

结论: 根据试验结果, 该试样燃烧性能符合 GB 50222-1995(2001 年修订)中关于顶棚、墙面、隔断装修材料 B1 级的要求。

接下页...



SGS-CSTC (Shanghai) Technical Services Co., Ltd.
Anji Branch Hardlines

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

No. 301, Sunlight Road, 2 Block, Sunlight Industry Zone, Anji County, Zhejiang Province, China 313300 t (86-572) 5018825 f (86-572) 5018829 www.sgs.com.cn
中国·浙江·安吉县阳光工业园二区阳光大道301号 邮编: 313300 t (86-572) 5018825 f (86-572) 5018829 e sgs.china@sgs.com

检测报告

报告号: AJFS1711009986FF_CN 日期: 2017年11月27日 第 3 页 共 5 页

附录 1: 难燃性测试

I. 试验方法

本测试是参照 GB/T 8625- 2005 建筑材料难燃性试验方法来进行测试操作。

II. 样品描述

名称	墙布
颜色	白色
样品尺寸	1000mm×190mm 16片

备注: 样品为墙布粘贴于约 0.48mm 厚的金属基材上 (客户提供)。

	温度 (°C)	湿度 (%)	处理时间 (d)
预处理	23±2	50±5	>7

III. 测试结果

测试项目	第一组				第二组				第三组				第四组			
燃烧剩余长度，mm	243	208	245	258	244	263	252	258	214	232	228	241	233	252	247	238
燃烧剩余长度平均值，mm	241															
平均烟气温度峰值，℃	164.3				160.4				164.1				162.8			
试样是否点燃，（是/否）	是				是				是				是			
试验火焰停止后试件有无阴燃，（有/无）	无				无				无				无			
滴落和脱落物在筛底继续燃烧 20s 以上，（是/否）	否				否				否				否			
其他现象	无															

接下页...



SGS-CSTC 检测技术有限公司
Anji Branch Hardlines

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

No. 301, Sunlight Road, 2 Block, Sunlight Industry Zone, Anji County, Zhejiang Province, China 313300 t (86-572) 5018825 f (86-572) 5018829 www.sgs.com
中国·浙江·安吉县阳光工业园二区阳光大道301号 邮编: 313300 t (86-572) 5018825 f (86-572) 5018829 e sgs.china@sgs.com

Member of the SGS Group (SGS SA)

检测报告

报告号: AJFS1711009986FF_CN 日期: 2017年11月27日 第4页共5页

附录 2: 可燃性测试

I. 测试标准

本试验按照 GB/T 8626-2007 建筑材料可燃性试验方法进行。

II. 样品描述

名称	墙布
颜色	白色
样品尺寸	250mm×90mm 6片

备注: 样品为墙布粘贴于约 0.48mm 厚的金属基材上 (客户提供)。

要求	温度 (°C)	湿度 (%)	处理时间 (d)
预处理	23±2	50±5	>7
施火时间	15s		

III. 试验结果

表面点火

	1	2	3
试验是否被引燃 (是/否)	否	否	否
火焰尖端是否达到150mm (是/否)	否	否	否
到达150 mm的时间	--	--	--
滤纸是否被引燃 (是/否)	否	否	否

边缘点火

	1	2	3
试验是否被引燃 (是/否)	是	是	是
火焰尖端是否达到150mm (是/否)	否	否	否
到达150 mm的时间	--	--	--
滤纸是否被引燃 (是/否)	否	否	否

备注: “--” 未到 150mm

陈述: 在特定的试验条件下, 试验结果与试样的性能有关; 试验结果不能作为评估制品在实际使用条件下潜在火灾危险性的唯一依据。

接下页...



SGS-CSTC Shanghai Technical Services Co., Ltd.
Anji Branch

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.
Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com
No. 301, Sunlight Road, 2 Block, Sunlight Industry Zone, Anji County, Zhejiang Province, China 313300 t (86-572) 5018825 f (86-572) 5018829 www.sgs.com.cn
中国·浙江·安吉县阳光工业园二区阳光大道301号 邮编: 313300 t (86-572) 5018825 f (86-572) 5018829 e sgs.china@sgs.com

检测报告

报告号: AJFS1711009986FF_CN 日期: 2017年11月27日 第 5 页 共 5 页

附录照片:



此照片仅限于随 SGS 正本报告使用

报告结束



SGS-CSTC 浙江安吉阳光工业园二区阳光大道301号
Anji Branch Hardlines

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

No. 301, Sunlight Road, 2 Block, Sunlight Industry Zone, Anji County, Zhejiang Province, China 313300 t (86-572) 5018825 f (86-572) 5018829 www.sgsgroup.com.cn
中国·浙江·安吉县阳光工业园二区阳光大道301号 邮编: 313300 t (86-572) 5018825 f (86-572) 5018829 e sgs.china@sgs.com