## **Simplex AO 16-Ch Terminal Block**

# KC4011X1-BM1 Simplex AO 16-Channel Terminal Block

#### Hazardous Atmosphere



II 3G Ex ec IIC Gc FM19ATEX0173U IECEx FMG 19.0019U FM21UKEX0017U



CL. I Div. 2 GP. A,B,C,D CL. I Zone 2 AEx/Ex ec IIC Gc FM17CA0145U FM17US0286U

#### **Power Specifications**

Field Circuit 30 VDC at 200 mA/Channel

#### **Environmental Specifications**

Ambient Temperature -40 °C to +70 °C

Shock 10 g half-sine wave for 11 ms

Vibration 1 mm peak to peak from 2 to 13.2

Hz; 0.7 g from 13.2 to 150 Hz

Airborne ISA-S71.04 –1985 Airborne Contaminants Class G3

Relative Humidity 5 to 95% Non-Condensing

Terminal block key

position

A5

**Note:** Refer to the product label for serial number and location and date of manufacture.

**Warning**: This product has specific instructions for installation, removal and operation in hazardous areas. Refer to document 12P2046 "DeltaV<sup>TM</sup> Scalable Process System Zone 2 Installation Instructions". Other installation instructions are

available in the "DeltaV<sup>TM</sup> S-series and CHARMs Hardware Installation" manual.

#### Removal and Insertion

Terminals Block can be added or removed with System Power applied only when no I/O Card is installed, and no field wiring is connected to the terminal.

A rotary keying system ensures compatibility between I/O cards and terminal blocks after installation is complete. The terminal block must have the keys set for the I/O card with which it is to be used.

#### Maintenance and Adjustment

This unit contains no user serviceable parts and should not be disassembled for any reason. Calibration is not required.

### Other Safety Approvals



